



CITY OF AUSTIN
STANDARD PRODUCTS LIST
for
CONCRETE STEEL CYLINDER PIPE

USING DEPARTMENT: Austin Water

PREPARED BY: Bill Flynn, P.E.

ISSUED: 04/28/78

REVISED BY: Jeff A. Kyle, P.E.

REVISED: 04/01/22

DESCRIPTION: Pipe, concrete steel cylinder shall comply with the following:
1. AWWA C301 (any size)
2. AWWA C303 (24" maximum diameter: not permitted in easements on private property)

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
04/28/78	THOMPSON PIPE GROUP – PRESSURE (formerly Forterra / Hanson Pressure Pipe) 1003 N. MacArthur Blvd. Grand Prairie, TX 75050	See notes	W. Flynn

NOTES:

1. For pipe larger than 24" diameter, manufacturer must provide one of the following with project submittal: a) evidence of current ISO registration, b) evidence of current Austin Water-approved quality control program, or c) name and qualifications of independent, third party firm that will test and inspect pipe produced for City of Austin, as per Standard Specification Item 510.

LATEST REVISIONS (since 01/01/16):

1. Updated to new SPL format.
2. Updated 'Forterra / Hanson Pressure Pipe' to 'Thompson Pipe Group – Pressure.'