

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 04/01/2023 - 04/30/2023

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP	
pH	SU	Avg	9.7	Avg	9.7	Avg	9.6	
		Max	9.8	Max	9.7	Max	9.6	
		Min	9.6	Min	9.6	Min	9.5	
Total Alkalinity	mg/L as CaCO3	Avg	66	Avg	62	Avg	83	
		Max	71	Max	64	Max	87	
		Min	59	Min	58	Min	79	
Total Hardness	mg/L as CaCO3	Avg	102	Avg	99	Avg	111	
		Max	107	Max	100	Max	115	
		Min	95	Min	95	Min	106	
Total Solids	mg/L	Avg	219	Avg	233	Avg	232	
		Max	248	Max	240	Max	246	
		Min	206	Min	224	Min	224	
Total Chloramines	mg/L	Avg	2.68	Avg	2.52	Avg	2.72	
		Max	2.80	Max	2.65	Max	2.80	
		Min	2.55	Min	2.40	Min	2.55	
Total Organic Carbon	mg/L	Avg	2.84	Avg	2.72	Avg	2.80	
		Max	2.97	Max	2.83	Max	2.83	
		Min	2.72	Min	2.62	Min	2.77	
Conductivity	umhos/cm	Avg	373	Avg	367	Avg	399	
		Max	375	Max	367	Max	399	
		Min	370	Min	367	Min	399	
Total Trihalomethanes	ug/L	Avg	31.1	Avg	28.5	Avg	26.8	
		Max	31.1	Max	28.5	Max	26.8	
		Min	31.1	Min	28.5	Min	26.8	
Turbidity	NTU	Avg	.06	Avg	.02	Avg	.04	
		Max	.08	Max	.04	Max	.07	
		Min	.04	Min	.02	Min	.02	