

Drinking Water Quality Report  
Date Range: 01-APR-2019 to 30-APR-2019

Parameter	Units	Method Cd	Davis WTP		Ullrich WTP		WTP 4	
				T2,T2H		T3		T4
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.6	AVG	9.6
			MAX	9.7	MAX	9.8	MAX	9.7
			MIN	9.5	MIN	9.5	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	58	AVG	57	AVG	65
			MAX	65	MAX	62	MAX	70
			MIN	51	MIN	52	MIN	62
Total Hardness	MG/L	SM 2340 C	AVG	84	AVG	84	AVG	87
			MAX	91	MAX	89	MAX	96
			MIN	78	MIN	80	MIN	83
Total Solids	MG/L	SM 2540 B	AVG	141	AVG	142	AVG	155
			MAX	164	MAX	156	MAX	174
			MIN	124	MIN	134	MIN	136
Chloramines	MG/L	SM 4500-CL F	AVG	2.86	AVG	2.65	AVG	2.75
			MAX	2.9	MAX	2.7	MAX	2.85
			MIN	2.8	MIN	2.6	MIN	2.65
Sulfate	MG/L	SM 4500-SO4 E	AVG	11.6	AVG	9.2	AVG	32.3
			MAX	11.6	MAX	9.2	MAX	32.3
			MIN	11.6	MIN	9.2	MIN	32.3
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.71	AVG	2.6	AVG	2.76
			MAX	2.84	MAX	2.8	MAX	2.89
			MIN	2.42	MIN	2.5	MIN	2.62
Conductivity	UMHOS/cm	SM 2510 B	AVG	268	AVG	263	AVG	309
			MAX	269	MAX	263	MAX	309
			MIN	267	MIN	263	MIN	309
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	34.1	AVG	33.9	AVG	33.2
			MAX	41.5	MAX	37.6	MAX	38.2
			MIN	25.4	MIN	31.3	MIN	30.3
Turbidity	NTU	SM 2130 B	AVG	0.04	AVG	0.02	AVG	0.03
			MAX	0.07	MAX	0.05	MAX	0.07
			MIN	0.02	MIN	0.02	MIN	0.02