

Drinking Water Quality Report  
Date Range: 01-DEC-2019 to 31-DEC-2019

| Parameter             | Units    | Method Cd     | Davis WTP |        | Ullrich WTP |      | WTP 4 |      |
|-----------------------|----------|---------------|-----------|--------|-------------|------|-------|------|
|                       |          |               |           | T2,T2H |             | T3   |       | T4   |
| pH                    | SU       | SM 4500-H B   | AVG       | 9.6    | AVG         | 9.6  | AVG   | 9.6  |
|                       |          |               | MAX       | 9.7    | MAX         | 9.7  | MAX   | 9.6  |
|                       |          |               | MIN       | 9.5    | MIN         | 9.4  | MIN   | 9.5  |
| Total Alkalinity      | MG/L     | SM 2320 B     | AVG       | 65     | AVG         | 63   | AVG   | 69   |
|                       |          |               | MAX       | 73     | MAX         | 71   | MAX   | 80   |
|                       |          |               | MIN       | 61     | MIN         | 57   | MIN   | 65   |
| Total Hardness        | MG/L     | SM 2340 C     | AVG       | 92     | AVG         | 90   | AVG   | 91   |
|                       |          |               | MAX       | 99     | MAX         | 97   | MAX   | 103  |
|                       |          |               | MIN       | 88     | MIN         | 82   | MIN   | 86   |
| Total Solids          | MG/L     | SM 2540 B     | AVG       | 147    | AVG         | 149  | AVG   | 164  |
|                       |          |               | MAX       | 184    | MAX         | 178  | MAX   | 198  |
|                       |          |               | MIN       | 122    | MIN         | 126  | MIN   | 138  |
| Chloramines           | MG/L     | SM 4500-CL F  | AVG       | 2.97   | AVG         | 2.83 | AVG   | 2.79 |
|                       |          |               | MAX       | 3.15   | MAX         | 3.00 | MAX   | 3.00 |
|                       |          |               | MIN       | 2.85   | MIN         | 2.55 | MIN   | 2.55 |
| Sulfate               | MG/L     | SM 4500-SO4 E | AVG       | 40.4   | AVG         | 41.8 | AVG   | 42.2 |
|                       |          |               | MAX       | 41.1   | MAX         | 41.8 | MAX   | 42.2 |
|                       |          |               | MIN       | 39.7   | MIN         | 41.8 | MIN   | 42.2 |
| Total Organic Carbon  | MG/L     | SM 5310 C     | AVG       | 2.59   | AVG         | 2.44 | AVG   | 2.43 |
|                       |          |               | MAX       | 2.83   | MAX         | 2.64 | MAX   | 2.49 |
|                       |          |               | MIN       | 2.42   | MIN         | 2.23 | MIN   | 2.36 |
| Conductivity          | UMHOS/cm | SM 2510 B     | AVG       | 273    | AVG         | 274  | AVG   | 301  |
|                       |          |               | MAX       | 273    | MAX         | 274  | MAX   | 301  |
|                       |          |               | MIN       | 272    | MIN         | 274  | MIN   | 301  |
| Total Trihalomethanes | UG/L     | EPA 524.3 THM | AVG       | 29.5   | AVG         | 34.0 | AVG   | 32.6 |
|                       |          |               | MAX       | 34.6   | MAX         | 38.1 | MAX   | 37.2 |
|                       |          |               | MIN       | 23.1   | MIN         | 28.7 | MIN   | 30.3 |
| Turbidity             | NTU      | SM 2130 B     | AVG       | 0.05   | AVG         | 0.04 | AVG   | 0.03 |
|                       |          |               | MAX       | 0.13   | MAX         | 0.08 | MAX   | 0.05 |
|                       |          |               | MIN       | 0.03   | MIN         | 0.04 | MIN   | 0.02 |