

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 01/01/2021 - 01/31/2021

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP*
pH	SU	Avg	9.6	Avg	9.6	Avg	9.6
		Max	9.7	Max	9.7	Max	9.6
		Min	9.5	Min	9.4	Min	9.4
Total Alkalinity	mg/L as CaCO3	Avg	71	Avg	62	Avg	74
		Max	76	Max	67	Max	78
		Min	67	Min	55	Min	69
Total Hardness	mg/L as CaCO3	Avg	103	Avg	94	Avg	98
		Max	110	Max	98	Max	101
		Min	97	Min	90	Min	94
Total Chloramines	mg/L	Avg	2.97	Avg	2.68	Avg	2.75
		Max	3.05	Max	2.80	Max	2.85
		Min	2.85	Min	2.50	Min	2.65
Total Organic Carbon	mg/L	Avg	2.60	Avg	2.42	Avg	2.44
		Max	2.68	Max	2.48	Max	2.52
		Min	2.44	Min	2.33	Min	2.41
Total Trihalomethanes	ug/L	Avg	15.9	Avg	25.2	Avg	21.9
		Max	16.3	Max	25.2	Max	21.9
		Min	15.6	Min	25.2	Min	21.9
Turbidity	NTU	Avg	0.07	Avg	0.03	Avg	0.03
		Max	0.13	Max	0.16	Max	0.04
		Min	0.06	Min	0.02	Min	0.02

Due to Covid-19 the number of parameters analyzed has been reduced effective 3-27-20.

*WTP4 was renamed as Handcox WTP. Moving forward this plant will be referred to as Handcox WTP.