

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 06/01/2021 and 06/30/2021

Parameter	Units	Davis WTP			Ullrich WTP			Handcox WTP
pH	SU	Avg	9.7	Avg	9.7	Avg	9.6	
		Max	9.8	Max	9.8	Max	9.6	
		Min	9.5	Min	9.4	Min	9.5	
Total Alkalinity	mg/L as CaCO3	Avg	47	Avg	49	Avg	73	
		Max	50	Max	54	Max	77	
		Min	44	Min	40	Min	70	
Total Hardness	mg/L as CaCO3	Avg	87	Avg	92	Avg	98	
		Max	91	Max	99	Max	102	
		Min	82	Min	84	Min	96	
Total Solids	mg/L	Avg	201	Avg	202	Avg	207	
		Max	238	Max	246	Max	222	
		Min	180	Min	162	Min	186	
Total Chloramines	mg/L	Avg	2.89	Avg	2.83	Avg	2.79	
		Max	3.05	Max	3.00	Max	2.90	
		Min	2.75	Min	2.65	Min	2.60	
Total Organic Carbon	mg/L	Avg	2.32	Avg	2.29	Avg	2.32	
		Max	2.43	Max	2.36	Max	2.37	
		Min	2.17	Min	2.22	Min	2.26	
Total Trihalomethanes	ug/L	Avg	41.2	Avg	44.8	Avg	23.2	
		Max	44.0	Max	44.8	Max	23.2	
		Min	38.4	Min	44.8	Min	23.2	
Turbidity	NTU	Avg	0.06	Avg	0.03	Avg	0.03	
		Max	0.07	Max	0.06	Max	0.07	
		Min	0.04	Min	0.02	Min	0.02	

Due to Covid-19 the number of parameters analyzed has been reduced effective 03/27/2020.